



ATTESTAZIONE FINALE

manufacturer:

AERMEC S.p.A.

Via Roma, 996 - 37040 Bevilacqua (VR) - Italy

referring to product(s):

<i>Description</i>	AIR TREATMENT UNITS
<i>Type</i>	NCD
<i>Identification code/sn</i>	85xxxxx VDI 6022
	85xxxxx DIN 1946
<i>Standard(s)</i>	VDI 6022 - Blatt 1 / Part 1 - 01/2018 Ventilation and indoor-air quality Hygiene requirements for ventilation and air-conditioning systems and units RLT guidelines 01 - General requirements for Air Handling Units Issue February 2018
	DIN 1946-4:2018-09 Ventilation and air conditioning Part 4: Ventilation in buildings and rooms of health care DIN 1946-4 Beiblatt 1:2018-06 Ventilation and air conditioning - Part 4: Ventilation in buildings and rooms of health care - Supplement 1: Checklist for planning, execution and operation of components
<i>Test Result</i>	Products conform to applicable requirements (refer to inspection report n° 76905-2 rev. 00 of 30/5/2023)

Page 1 of 1

Certificate issue: 12.06.2023
Valid Until: 11.06.2026
N° of certificate registration: 202376905-2

EUROCERTIFICATIONS S.r.l.

Elena Augroletti

